

CERTIFICATE OF COMPLIANCE

Certificate Number 20180629-R15431
Report Reference R15431-20070816
Issue Date 2018-JUNE-29

Issued to: HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC
7250 Dallas Pky, Legacy Tower Ste 1000
Plano TX 75024

**This is to certify that
representative samples of**

FIRESTOP DEVICES

Firestop devices for use in specific through-penetration firestop systems. The various suffixes for the designations of the firestop devices indicate the size of the device.

Models:

CP 653 2" Speed Sleeve, CP 653 4" Speed Sleeve.

CFS-SL GA L 2" and 4" Speed Sleeves

CP653 4" BA ILS, CFS-SL GA L ILS Speed Sleeves


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 1479, Fire Tests of Penetration Firestops
CAN/ULC S115, Method of Fire Tests of Firestops Systems

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

